

# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials



Awarded to: **NUDO PRODUCTS, INC.**  
1500 TAYLOR AVENUE, SPRINGFIELD, IL 62703

Category: Construction Material - Wallcovering  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

\*Conforms With: Criteria of MAS Certified Green® Program  
LEED v4.1 & v5.0 ID+C, BD+C  
LEED TVOC Emissions at 14-days  
LEED TVOC Emissions at 14-days  
US-CHPS 2020 Criteria (R2022) EQ C6.1.6  
*low-emitting materials*  
*low-emitting materials*  
*0.5 mg/m<sup>3</sup> or less (classroom)*  
*0.5 mg/m<sup>3</sup> - 5.0 mg/m<sup>3</sup> (private office)*  
*ceiling & wall systems*

Certified Products: BioProtect Wall and Ceiling Panel

Test Date: June 17, 2025      Report No.:2500361      Certificate No.: MAS2500361

**Valid: June 2025 to June 2026**



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>